



REQUEST FOR BIDS
Rooftop Air Exchanger Refurbishments
DULUTH TRANSIT AUTHORITY

Addendum #4

October 31, 2019

A. Please note: The Bid Due Date for responses to the Rooftop Air Exchanger Refurbishments HAS BEEN CHANGED to:

2:00 p.m. on Wednesday, November 13, 2019.

B. Clarification:

1. Please disregard Section B, paragraph 3 of Addendum 2: ~~%The project includes repacking the pillow block bearings. There are two bearings per motor, a total of 18 bearings in all. The cost for repacking the bearing should be included in the base price of the work.+~~

The DTA would like all bearings to be REPLACED. Please revises the paragraph as follows:

~~%~~The project includes **replacing** the pillow block bearings. There are two bearings per motor, a total of 18 bearings in all. The cost for replacing the bearings shall be included in the base price of the work.+

2. The deadline to submit question has been extended to Tuesday, November 5, 2019, Responses to questions will be posted to the DTA website at www.duluthtransit.com on Wednesday, November 6, 2019.