



REQUEST FOR BIDS
Overhead Heater Replacements

DULUTH TRANSIT AUTHORITY

Addendum #1

July 3, 2023

1. Please note: The Bid due date HAS BEEN CHANGED to **2:00 p.m. on THURSDAY, July 13, 2023.** Please change all references to the Bid Due date accordingly.
2. The DTA held a prebid meeting on June 22, 2023. Attendees were Dean Birman, Hunt Electric, Brian Schmidt, Johnson Controls, Mark Ness, Justin Arnold, Nancy Brown, DTA.
3. The DTA prefers to replace one unit for two units to allow one unit to act as the primary recovery heater at the entrance and exit door and the second heater to activate during extreme cold or when the primary unit is not operational. They should be controlled by thermostat.
4. Each set of heaters will require controls and additional wiring for the secondary heater. Expenses for the controls and wiring will be borne by the Bidder.
5. Drawings for the mechanical system in the building are on the DTA website. Please note Section 6 that details the brand of the original heaters and the associated controls and wiring.
6. Further questions will be accepted until Friday, July 7, 2023.