



REQUEST FOR BIDS
Overhead Heater Replacements (Reissue)

DULUTH TRANSIT AUTHORITY

Addendum #1

August 16, 2023

1. Clarifications to Date:

- a. Section 6, Technical Specifications, paragraph A2, please change the minimum Btu/h required from 600,000 Btu/h each to 300,000 Btu/h each:
 - “2. In lieu of the large heaters at three doors, the DTA would like to convert them to two sets of heaters, a minimum of ~~600,000~~ 300,000 Btu/h each, at each door similar to the main entrance door. One heater will be programmed to provide recovery heat when a door is open for a short period of time or in moderate weather, the second heater at each door is to be programmed to provide supplemental heat if the door is open longer.”
- b. The power available for the heaters is a 15 amp breaker, 12 gauge wire. There is a thermostat on each heater; a new thermostat will be required for the new heaters that will be installed.