

A.W. KUETTEL & SONS I N C

Plumbing, Heating & Ventilation / Air
Conditioning / Sheet Metal /
Roofing-Asphalt, Pitch & Gravel
Tile, Slate / Siding / Fire Protection

H07093

August 14, 2017

Peggy Billings,

Attached is the recorded hydrant flow test information for the location of 1912 W Michigan Street that we conducted with the City on August 14, 2017 at 1:15 pm.

Static: 114 psi
Residual: 106 psi
Pitot: (1) at 70 psi
Outlet: (1) nozzles at 2 ½"
Flow: 1,411 GPM

The gauged hydrant was the hydrant on the corner of the W Michigan and S 20th Avenue W intersection. The flowing hydrant was on the W Michigan and S 19th Avenue intersection.

Thank you very much,

Dustin Melin
Dmelin@awkuettel.com

A.W. Kuettel & Sons
3930 Airpark Blvd.
Duluth, MN 55811

218-590-1289 cell
218-722-3901 office
218-722-6113 fax